

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:	
PS1	WF-1	Hallway next to 114-A (lower faucet)	Water Fountain	< 3.0 ppb		<2.0 ppb										
	WF-2	Hallway next to 114-A (upper faucet)	Water Fountain	< 3.0 ppb		<2.0 ppb										
	WF-3	Hallway next to 215-A (lower faucet)	Water Fountain	< 3.0 ppb		<2.0 ppb										
	WF-4	Hallway next to 215-A(upper faucet)	Water Fountain	< 3.0 ppb		<2.0 ppb										
	SF-1	Classroom - 1	Sink Faucet	< 3.0 ppb		Tested under PS 26										
	SF-2	Classroom - 2	Sink Faucet	< 3.0 ppb		Tested under PS 26										
	SF-3	Classroom - 3	Sink Faucet	< 3.0 ppb		Tested under PS 26										
	SF-4	Classroom - 4	Sink Faucet	< 3.0 ppb		Tested under PS 26										
	SF-5	Classroom - 5	Sink Faucet	< 3.0 ppb		Trailers removed										
	SF-6	Classroom - 6	Sink Faucet	< 3.0 ppb		Trailers removed										
	SF-7	Classroom - 7	Sink Faucet	< 3.0 ppb		Trailers removed										
SF-8	Classroom - 8	Sink Faucet	< 3.0 ppb		Trailers removed											
SF-9	Classroom - 10	Sink Faucet	< 3.0 ppb		Trailers removed											
SF-10	Classroom - 11	Sink Faucet	< 3.0 ppb		Trailers removed											
SF-11	Shared Nurse's office PS1/PS26	Sink Faucet	See Note										Shared nurses office with school PS26			
PS2	SF-1	Basement Kitchen single	Sink Faucet	1.3 ppb		<2.0 ppb							Lab ran out of bottles. 2 DIFFERENT DAYS OF SAMPLING. Sinks that tested high have not been in use. They were turned on for sampling.			
	SF-2	Basement Kitchen Triple	Sink Faucet	N/A		6.4 ppb										
	SF-3	Nurse's office	Sink Faucet	N/A		<2.0 ppb										
	SF-4	Room 103	Sink Faucet	N/A		11 ppb										
	SF-5	Room 107	Sink Faucet	N/A		41 ppb	95529- withdrawn	see note						this is non potable water which was turned on just for the sampling. Signage has been posted NON POTABLE water.		
	SF-6	Room 109	Sink Faucet	N/A		17 ppb	95530- withdrawn	see note						this is non potable water which was turned on just for the sampling. Signage has been posted NON POTABLE water.		
	SF-7	Teacher's lounge	Sink Faucet	N/A		4.8 ppb								No sink in the teachers lounge		
	SF-8	NB 2ND FL. room 26	Sink Faucet	N/A		<2.0 ppb										
	SF-9	NB 2nd fl. Room 41	Sink Faucet	N/A		<2.0										
	SF-10	NB 2nd. Fl Room 32 back	Sink Faucet	N/A		70 ppb	95528- withdrawn	see note						this is non potable water which was turned on just for the sampling. Signage has been posted NON POTABLE water.		
	SF-11	NB 2nd fl. Room 32 front	Sink Faucet	N/A		<2.0 ppb										
	SF-12	NB 2nd. Fl. Room 30	Sink Faucet	N/A		<2.0 ppb										
	SF-13	NB 2nd fl. Room 38	Sink Faucet	N/A		2.7 ppb										
	SF-14	NB 1st Fl Room 16	Sink Faucet	N/A		<2.0 ppb										
	SF-15	NB 1st Fl Room 17	Sink Faucet	N/A		<2.0 ppb										
	SF-16	NB 1st. Fl Room 9	Sink Faucet	N/A		<2.0 ppb										
	SF-17	NB 1st. Fl. Room 6	Sink Faucet	N/A		<2.0 ppb										
	SF-18	NB 3rd Fl Library	Sink Faucet	N/A		4.5 ppb										
	WF-1	Basement Cafeteria	Water Fountain - Elkay			1.1ppb										
WF-2	Basement Across from Art Studio (left)	Water Fountain			5.3 ppb											
WF-3	Basement Across from Art Studio (right)	Water Fountain			12 ppb								Missing sample/Lab to be contacted			
WF-4	2nd floor across from 202 (right)	Water Fountain	Fountain Removed			7.7ppb							Fountain removed and replaced			
WF-5	Room103	Water Fountain				7.8 ppb										
WF-6	Across from 102 (left)	Water Fountain - Acorn				N/D										
WF-7	Across from 102 (right)	Water Fountain - Acorn				2.3 ppb										
WF-8	Across from 110 (left)	Water Fountain - Elkay				20 ppb	6.6 ppb									
WF-9	Across from 110 (right)	Water Fountain - Elkay				2.9 ppb										
WF-10	Across from 202 (left)	Water Fountain - Elkay				3.9 ppb										
WF-11	Across from 210 (left)	Water Fountain				8.4 ppb										
WF-12	Across from 210 (right)	Water Fountain-Elkay				5.2 ppb										
WF-13	Across from 310 (left)	Water Fountain-Parcelain				10 ppb										
WF-14	Across from 310 (right)	Water Fountain-Elkay				<3.0 ppb										
WF-15	Next to Kidergarten #3	Water Fountain-Elkay				N/D										
WF-16	Across from 23 (left)	Water Fountain-Elkay				N/D										
WF-17	Room 6	Water Fountain-Elkay				2.7 ppb										
WF-18	Classroom 16	Water Fountain-Elkay				N/D										
WF-19	NB 2ND FL by room 30	water fountain				N/A										
PS3	SF-1	Kitchen Basement	Sink Faucet	< 3.0 ppb		<2.0 ppb										
	SF-2	2nd Floor Nurse Office	Sink Faucet	< 3.0 ppb		<2.0 ppb										
	SF-3	Teacher's lounge	Sink Faucet	N/A		N/A										
	WF-1	1st Fl Corridor #1 left near rm 4	Water Fountain			<3.0 ppb										
	WF-2	1st Fl Corridor #2, Right near rm 4	Water Fountain			<3.0 ppb										
	WF-3	1st Fl Corridor #3,Boy's restroom far right	Water Fountain			<3.0 ppb										
	WF-4	1st Fl Corridor #4, center	Water Fountain			< 3.0 ppb										
	WF-5	1st Fl Corridor #5, left	Water Fountain			< 3.0 ppb										
WF-6	2nd floor Corridor next to 204	Water Fountain			< 3.0 ppb	120 ppb	95484	46 ppb					tentative week of May 30			
WF-7	2nd floor Corridor next to 206	Water Fountain			49 ppb	<3.0 ppb	95845	71 ppb					tentative week of May 30			
WF-8	3rd floor Corridor next to 305	Water Fountain			6.4 ppb	7.0 ppb										
PS3 TRAILERS	SF-1	Trailer 3	sink faucet	N/A		<3.0 ppb										
	SF-2	Trailer 2	sink faucet	N/A		<2.0 ppb										
	SF-3	Trailer 1	sink faucet	N/A		290 ppb	see note						The 3 sinks in the trailers are for hand washing. There are water coolers in each trailer. Signage will be placed.			
PS4	SF-1	Kitchen	Sink Faucet	< 3.0 ppb		< 3.0ppb										
	SF-2	Room 105	Sink Faucet	< 3.0 ppb		< 3.0ppb										
	SF-3	Nurse Office	Sink Faucet	< 3.0 ppb		< 3.0ppb										
	SF-4	2nd Floor Teachers Lounge	Sink Faucet	< 3.0 ppb		<3.0ppb										

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	SF-5	4th Floor Teachers Lounge	Sink Faucet	4.1 ppb		3.7ppb									
	WF-1	1st Floor next to Boys Room (L)	Water Fountain	< 3.0 ppb		<3.0ppb									
	WF-2	1st Floor next to Boys Room (R)	Water Fountain	< 3.0 ppb		<3.0ppb									
	WF-3	1st Floor next to Girls Room (L)	Water Fountain	< 3.0 ppb		< 3.0ppb									
	WF-4	1st Floor next to Girls Room (R)	Water Fountain	< 3.0 ppb		N/A									
	WF-5	2nd Floor H/W by Nurse Office	Water Fountain	7.5 ppb		8.7ppb									
	WF-6	2nd Floor H/W by room 209	Water Fountain	56 ppb	22ppb	<3.0ppb									
	WF-7	3rd Floor H/W by room 313	Water Fountain	<3.0 ppb		< 3.0ppb									
	WF-8	3rd Floor H/W by room 303	Water Fountain	<3.0 ppb		< 3.0ppb									
	WF-9	4th Floor H/W by room 403	Water Fountain	<3.0 ppb		< 3.0ppb									
PS5															
	SF-1	Basement Kitchen	Sink Faucet	< 3.0 ppb		< 3.0ppb									
	SF-2	Custodian Office	Sink Faucet	< 3.0 ppb		<3.0ppb									
	SF-3	Nurses Office	Sink Faucet	11 ppb		7.4ppb									
	SF-4	1st Floor Teachers Room	Sink Faucet	5.7 ppb		3.5ppb									
	SF-5	G 100 BN	Comm Service Sink	37 ppb	<3.0	< 3.0ppb									
	SF-6	3rd Floor Teachers Lounge	Sink Faucet	9.6 ppb		5.6ppb									
	WF-1	3rd Floor Hall by Room 303	Water Fountain	< 3.0 ppb		<3.0ppb									
	WF-2	3rd Floor by Room 308A	Water Fountain	6.2 ppb		12ppb									
	WF-3	2nd Floor by Room 222	Water Fountain	< 3.0 ppb		< 3.0ppb									
	WF-4	2nd Floor Adj. to Room 218	Water Fountain	< 3.0 ppb		150ppb	94695	FD <2.0 ppb, Flush 4.7 ppb							
	WF-5	1st Floor by Room 108	Water Fountain	< 3.0 ppb		< 3.0ppb									
	WF-6	1st Floor Adj. to Room 120	Fountain Bubble	3.0 ppb		27ppb	94695	FD 3.7ppb, flush <2.0 ppb							
PS6															
	WF-1	1st Floor Adjacent to Room 106	Water Fountain-Elkay	70 ppb	7.4 ppb	12ppb		<2.0 ppb							
	WF-2	1st Floor Adjacent to Room 113	Water Fountain-Elkay	<3.0 ppb		< 2.0ppb									
	WF-3	Basement adjacent to Cafeteria - Lower	Water Fountain-Elkay	4.4ppb		4.5ppb									
	WF-4	Basement adjacent to Cafeteria -Upper	Water Fountain-Elkay	230 ppb	24 ppb	10ppb		<2.0 ppb							
	WF-5	2nd Floor Adjacent to Room 206 Upper	Water Fountain -	8.5 ppb		<3.0ppb									
	WF-6	2nd Floor Adjacent to Room 206 Lower	Water Fountain -	<3.0ppb		5.3ppb									
	WF-7	2nd Floor Adjacent to Room 209 Upper	Water Fountain	31 ppb	<3.0 ppb	4.8ppb		<2.0 ppb							
	WF-8	2nd Floor Adjacent to Room 209 Lower	Water Fountain	8.4 ppb		5.7ppb									
	WF-9	3rd Floor Adjacent to Room 306- Upper	Water Fountain-Elkay	3.2 ppb		Out of Service	92483	3.8 ppb							
	WF-10	3rd Floor Adjacent to Room 306- Lower	American Standard-Water Fountain	17 ppb		Out of Service	88924	Tentative week of May 30th.							
	WF-12	3rd Floor Adjacent to Room 309 -Upper	Water Fountain	See Note		5.3ppb							COC not clear. Will resample as a precaution. Analysis not completed by Lab		
	WF-11	3rd Floor Adjacent to Room 309 - Lower	Water Fountain	15 ppb		7.5ppb		6.1 ppb							
	SF-1	Kitchen	Sink Faucet (1)	<3.0 ppb		< 3.0ppb									
	SF-2	Kitchen	Sink Faucet (3)	<3.0 ppb		< 3.0ppb									
	SF-3	Nurse's Office	Sink Faucet	n/a		N/A *							WATER COOLER IN USE		
	SF-4	Teacher's Lounge(s)	Sink Faucet	n/a		N/A *							WATER COOLER IN USE		
PS7															
	SF-1	Kitchen Basement	Sink Faucet	4.1 ppb		< 3.0ppb									
	SF-2	Teachers Lounge Basement	Sink Faucet	14 ppb		< 3.0ppb									
	SF-3	2nd Floor Nurse Office	Sink Faucet	13 ppb		3.5ppb									
	WF-1	Cafeteria Basement-Right	Water Fountain	7.9ppb		3.2ppb									
	WF-2	Cafeteria Basement-Left	Water Fountain	9.6ppb		7.1 ppb									
	WF-3	2nd Floor Corridor adjacent to room 204 - right	Water Fountain	11ppb		85ppb	94479	FD 6.7 ppb, Flush <2.0 ppb							
	WF-4	2nd Floor Corridor adjacent to room 204 - left	Water Fountain	17ppb		12ppb									
	WF-5	2nd Floor Corridor adjacent to Nurse Office	Water Fountain	6.7ppb		<3.0ppb									
	WF-6	3rd Floor Corridor adjacent to room 209	Water Fountain	14ppb		10ppb									
	WF-7	3rd Floor Corridor adjacent to room 214	Water Fountain	11ppb		32ppb	94477	FD 3.1 ppb, Flush 2.1 ppb							
	WF-8	Gymnasium	Water Fountain	See Note		4.2ppb							Water Fountain installed post-testing 2014-2015		
PS8															
	SF-1	Basement Kitchen	Sink Faucet	11 ppb		<3.0 ppb									
	SF-2	Nurse's Office	Sink Faucet	N/A		to be sampled		tentative week of May 30th							
	SF-7777	Teacher's lounge	need to confirm if there is a sink.					tentative week of May 30th							
	WF-1	Hallway next to BS - left	Water Fountain	6.3 ppb		7.12 ppb									
	WF-2	Hallway next to BS - right	Water Fountain	2.8 ppb		242 ppb	95761	tentative week of May 30th							
	WF-3	Hallway next to Chief Custodian Office	Water Fountain	4.0 ppb		out of service	is there a work order #	tentative week of May 30th							
	WF-4	Hallway next to Principal Office - left	Water Fountain	4.1 ppb		9.88 ppb									
	WF-5	Hallway next to Principal Office - right	Water Fountain	3.5 ppb		4.21 ppb									
	WF-6	Hallway adjacent to room 107 left	Water Fountain	3.3 ppb		4.08 ppb									
	WF-7	Hallway adjacent to room 107 right	Water Fountain	n/a		295 ppb	95760	tentative week of May 30th							
	WF-8	Hallway adjacent to room 209 left	Water Fountain	3.3 ppb		4.3 ppb									
	WF-9	Hallway adjacent to room 209 right	Water Fountain	n/a		616 ppb	95759	tentative week of May 30th							
	WF-10	Hallway adjacent to room 206 left	Water Fountain	4.3 ppb		4.3 ppb									
	WF-11	Hallway by Room 200 right	Water Fountain	n/a		140 ppb	95758	tentative week of May 30th							
PS9															
	WF-1	Basement adjacent D Stairs - left	Fountain-Elkay	2.8 ppb		<2.0 ppb									
	WF-2	Basement adjacent D Stairs - center	Fountain-Elkay	Out of service	Out of service	out of service	95989	tentative week of May 30th							
	WF-3	Basement adjacent D Stairs - right	Fountain-Taylor	1.3 ppb		<2.0 ppb									
	WF-4	Basement adjacent B Stairs - left	Fountain-Western	15 ppb		6.0 ppb									
	WF-5	Basement adjacent B Stairs - center	Fountain-Western	12 ppb		2.7 ppb									
	WF-6	Basement adjacent B Stairs - right	Fountain-Western	14 ppb		8.5 ppb									
	WF-7	1st Floor adjacent B1 Stairs - left	Fountain-Western	20 ppb	280 ppb/ 3rd Test 6.0ppb	38 ppb	95982	tentative week of May 30th							
	WF-8	1st Floor adjacent B1 Stairs - center	Fountain-Western	5.2 ppb		2.2 ppb									
	WF-9	1st Floor B1 Stairs - right	Fountain-Western	4.3 ppb		2.5 ppb									
	WF-10	Gym Boys Side-left	Fountain-Elkay	2.4 ppb		<2.0 ppb									
	WF-11	Gym Boys Side-right	Fountain-Elkay	1.3 ppb		<2.0 ppb									
	WF-12	Gym Girls Side-left	Fountain-Taylor	10 ppb		<2.0 ppb									
	WF-13	Gym Girls Side-right	Fountain-Taylor	13 ppb		<2.0 ppb									
	WF-14	1st fl adjacent 106 L.	Fountain-Taylor	3.3 ppb		<2.0 ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	SF-4	Nurses office	Sink Faucet			<2.0 ppb									
	SF-5	3rd fl science lab	Sink Faucet			9.6 ppb									
PS13															
	SF-1	Kitchen	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-2	Kitchen	Sink Faucet	N/A		<2.0 ppb									
	SF-3	Nurse's Office	Sink Faucet	N/A		<2.0 ppb									
	SF-4	room 8	Sink Faucet	N/A		<2.0 ppb									
	SF-5	room 7	Sink Faucet	N/A		<2.0 ppb									
	SF-6	Room 9	Sink Faucet	N/A		<2.0 ppb									
	SF-7	Room 10	Sink Faucet	N/A		<2.0 ppb									
	SF-8	Teacher's Lounge	No Outlets												
	SF-9	Parent Liasion Room	Sink Faucet	n/a		see note							This outlet is not in use and signage posted- Water source not tested DO not drink. 4/25/2016		
	WF-1	Basement by room 6-Left	Water Fountain	7.3 ppb		6.2 ppb									
	WF-2	Basement by room 6-Right	Water Fountain	<3.0 ppb		2.3 ppb									
	WF-3	Basement by Custodian Office L.	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-4	Basement by Custodian Office R.	Water Fountain	3.1 ppb		4.6 ppb									
	WF-5	Hallway by Room 16	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-6	Hallway by Room 21	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-7	Hallway by Room 31	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-8	Hallway by Room 36	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-9	Hallway by Main Office	Water Fountain	N/A		<2.0 ppb									
	WF-11	Room 7	Water Fountain	N/A		<2.0 ppb									
	WF-12	Room 9	Water Fountain	N/A		<2.0 ppb									
	WF-13	Room 26	Water Fountain	N/A		<2.0 ppb									
	WF-14	Room 10	Water Fountain	N/A		<2.0 ppb									
PS14															
	SF-1	Basement	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-2	Basement outside Girl's RR	Sink Faucet	see note		2.2 ppb									
	SF-3	2nd Floor hallway	Sink Faucet	see note		<2.0 ppb							not tested 2014-2015		
	SF-4	1st Floor hallway	Sink Faucet	see note		2.2 ppb							not tested 2014-2015		
	WF-1	Second fl Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-2	Second fl Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-3	First fl Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-4	First fl Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-5	Basement Left	Water Fountain	<3.0 ppb		3.4 ppb									
	WF-6	Basement Right	Water Fountain	<3.0 ppb		<2.0 ppb									
PS15															
	SF-01	Basement Kitchen	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-02	Nurse's Office	Sink Faucet	N/A				tentative week of May 30th.							
	SF-03	Teacher's Lounge(s)	Sink Faucet	N/A				tentative week of May 30th.							
	WF-1	Cafeteria A - Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-2	Cafeteria A - Left	Water Fountain	<3.0 ppb		98 ppb	95380	<2.0 ppb					Repaired same day by Chief. The fountain was leaking and had been turned off.		
	WF-3	Hallway across from rm. 114 - Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-4	Hallway across from rm. 114 - Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-5	Hallway across from rm. 106 - Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-6	Hallway across from rm. 106 - Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-7	Hallway across from rm. 205 - Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-8	Hallway across from rm. 205 - Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-9	Hallway across from rm. 214 - Right	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-10	Hallway across from rm. 214 - Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-11	Hallway across from rm. 314 - Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-12	Hallway across from rm. 314 - Right	Water Fountain	See note		<2.0 ppb									
	WF-13	Hallway across from rm. 305 - Right	Water Fountain	<3.0 ppb		<2.0 ppb							Not tested 2014-2015		
	WF-14	Hallway across from rm. 305 - Left	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-15	Hallway across B-6 Right	Water Fountain	See note		<2.0 ppb							Not tested 2014-2015		
	WF-16	Hallway across B-6 Left	Water Fountain	See note		<2.0 ppb							Not tested 2014-2015		
PS17															
	WF-1	2nd fl Hallway	Water Fountain-White	<3.0 ppb		5.6ppb									
	WF-2	1st floor Corridor	Water Fountain	See Notes									Unit removed per principal request		
	WF-3	Basement Cafeteria	Water Fountain - White	23 ppb	5.0 ppb	Out of Service	93918	tentative week of May 30th							
	WF-4	Basement Cafeteria	Water Fountain - Silver	7.4 ppb		<3.0ppb									
	SF-1	1st fl Principals Office	Sink Faucet	<3.0 ppb		4.1 ppb									
	SF-2	2nd fl Teachers Lounge	Sink Faucet	<3.0 ppb		<3.0ppb									
	SF-3	Basement Kitchen	Sink Faucet	<3.0 ppb		<3.0ppb									
PS18															
	WF-1	1st Floor adjacent to Rm. 106 - upper	Water Fountain-Elkay	5.5 ppb		15ppb	94676	<2.0ppb FD, <2.0 ppb FLUSH							
	WF-2	1st Floor adjacent to Rm. 106 - lower	Water Fountain-Elkay	<3.0 ppb		<3.0ppb									
	WF-3	2nd Floor Adjacent to Rm. 207 - upper	Water Fountain-Elkay	3.6 ppb		<3.0ppb									
	WF-4	2nd Floor Adjacent to Rm. 207 - lower	Water Fountain-Elkay	27 ppb	1.2 ppb	<3.0ppb									
	WF-5	3rd Floor adjacent to Rm.301 - upper	Water Fountain-Elkay	<3.0 ppb		<3.0ppb									
	WF-6	3rd Floor adjacent to Rm.301 - lower	Water Fountain-Elkay	7.3 ppb		<3.0ppb									
	WF-7	3rd Floor adjacent to Rm. 306 - upper	Water Fountain-Elkay	5.2 ppb		<3.0ppb									
	WF-8	3rd Floor adjacent to Rm 306 - lower	Water Fountain-Elkay	8.1 ppb		3.5ppb									
	WF-9	1st Floor Library	Water Fountain-Elkay	31 ppb	1.4 ppb	39ppb	94318	removed					Unit permanently removed		
	WF-10	Nurses Room #3 Hallway- Upper	Water Fountain	N/A		<3.0ppb									
	WF-11	Nurses Room #3 Hallway- Lower	Water Fountain	N/A		3.1ppb									
	SF-1	Kitchen	Sink Faucet	<3.0 ppb		<3.0ppb									
	SF-2	Teachers Room	Sink Faucet	15ppb		11ppb									
	SF-3	NURSE'S OFFICE	Sink Faucet	N/a				tentative week of May 30th							
PS 18 TRAILERS		Temp Classroom Units				AWAITING RESULTS									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
PS19	SF-1	Kitchen	Sink	<3.0 ppb		<2.0 ppb									
	SF-2	2nd Floor Nurses Room	Sink	<3.0 ppb		<2.0 ppb									
	SF-3	1st Floor Main Office Bathroom	Sink	<3.0 ppb		N/A									
	SF-4	Kitchen Sink Ceramic	Sink/Faucet	N/A		<2.0 ppb									
	SF-5	Kindergarten RR	Sink/Faucet	N/A		<2.0 ppb									
	SF-6	KINDERGARTEN RR	Sink/Faucet	N/A		<2.0 ppb									
	WF-1	1st Floor adjacent to Room 106	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-2	1st Floor adjacent to Room 104	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-3	1st Floor in Room 103	Water Fountain	<3.0 ppb		3.7 ppb									
	WF-4	2nd Floor adjacent to Stair A2	Water Fountain	<3.0 ppb		3.1 ppb									
	WF-5	2nd Floor Adjacent to Room 205	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-6	Basement Corridor adjacent to Kindergarten	Water Fountain	<3.0 ppb		6.0 ppb									
	WF-7R	Double Fountain right	Water Fountain	19 ppb		7.5 ppb									
	WF-7L	Double Fountain left	Water Fountain	N/A		2.1 ppb									
PS20	SF-1	Kitchen Basement - Old Building	Sink Faucet	3.8 ppb		4.28 ppb									
	SF-2	2nd Floor Nurses Office-New Building	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-3	2nd Floor Teachers Lounge	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-4	Chief Office Basement- New Bldg.	Sink Faucet	< 3.0ppb		N/A									
	SF-5	Former Nurse/Teacher Liaison Room	Sink Faucet	N/A		<3.0 ppb									
	SF-6	New Bldg. Teacher's Lounge	Sink Faucet	N/A		<3.0 ppb									
	WF-1	Café adj. Stair D	Water Fountain	<3.0ppb		6.72 ppb									
	WF-2	1st Floor Old Bldg. -left	Water Fountain	5.4ppb		<3.0 ppb									
	WF-3	1st Floor Old Bldg. -right	Water Fountain	8.9ppb		8.22 ppb									
	WF-4	2nd Floor Old Bldg. adj. RM. 14	Water Fountain	<3.0ppb		144 ppb	95763	5.5 ppb							
	WF-5	1st Floor New Bldg. Adj. RM. 107	Water Fountain	<3.0ppb		149 ppb	95765	19 ppb*					tentative week of May 30th.		
	WF-6	1st Floor New Bldg. Adj. RM. 103	Water Fountain	<3.0ppb		<3.0 ppb									
	WF-7	2nd Floor New Bldg. Adj. Stair AA2	Water Fountain	<3.0ppb		18.8 ppb	95766	<2.0 ppb							
	WF-8	2nd Floor New Bldg. Adj. RM. 203	Water Fountain	< 3.0ppb		<3.0 ppb									
WF-9	Basement New Bldg. Adj. B2	Water Fountain	<3.0ppb		251 ppb	95767	3.9 ppb								
WF-10	Basement New Bldg. Adj. Stair A	Water Fountain	<3.0ppb		<3.0 ppb										
PS21	WF-1	Across from B-4	Water Fountain-Taylor	<3.0 ppb		<3.0ppb									
	WF-2	Across from B-8	Water Fountain-Taylor	<3.0 ppb		<3.0ppb									
	WF-3	Across from 102	Water Fountain-Elkay	<3.0 ppb		<3.0ppb									
	WF-4	Across from 105	Water Fountain-Elkay	<3.0 ppb		4.5ppb									
	WF-5	Across from 106	Water Fountain-Elkay	<3.0 ppb		<3.0ppb									
	WF-6	Across from 109	Water Fountain-Elkay	3.8 ppb		<3.0ppb									
	WF-7	Inside 115	Water Fountain-Elkay	6.6 ppb		<3.0ppb									
	WF-8	Across from 209	Water Fountain-Elkay	Out of Service	See Notes	4.4ppb								Broken no flow/sampled not taken/Nov 2014	
	WF-9	Across from 205	Water Fountain-Elkay	<3.0 ppb		Out of Service	91922	13 ppb						Mechanical problem needs to be repaired	
	WF-10	Across from 206	Water Fountain-Elkay	<3.0 ppb		<3.0ppb									
	WF-11	Across from 202	Water Fountain-Elkay	6.4 ppb		<3.0ppb									
	WF-12	Across from 302	Water Fountain-Elkay	30 ppb	3.9 ppb	4.4ppb									
	WF-13	Across from 305	Water Fountain-Elkay	Out of Service		<3.0ppb									
	WF-14	Across from 306	Water Fountain-Elkay	<3.0 ppb		<3.0ppb									
	WF-15	Across from 309	Water Fountain-Elkay	Out of Service		3.7ppb									
	SF-1	Kitchen East	Sink Faucet	<3.0 ppb		<3.0ppb									
SF-2	Kitchen West	Sink Faucet	<3.0 ppb		<3.0ppb										
SF-3	2nd floor Teachers Lounge	Sink Faucet	12 ppb		13ppb										
SF-4	Classroom 112	Sink Faucet	<3.0 ppb		<3.0ppb										
SF-5	Classroom 113	Sink Faucet	<3.0 ppb		<3.0ppb										
SF-6	Inside 114	Sink Faucet	<3.0 ppb		<3.0ppb										
SF-7	Nurses Office Room 200	Sink Faucet	<3.0 ppb		<3.0ppb										
PS24	SF-1	Kitchen Double Sink	Sink Faucet	<3.0 ppb											
	SF-2	Kitchen Triple Sink	Sink Faucet	<3.0 ppb											
	SF-3	Nurse's Office	Sink Faucet	n/a											
	SF-4	Teacher's Lounge(s)	Sink Faucet	n/a											
	WF-1	Across from Room 002 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-2	Across from Room 002 - Upper	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-3	Gymnasium	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-4	Basement by Stairwell #1 - Upper	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-5	Basement by Stairwell #1 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-6	Basement by Stairwell #4	Water Fountain-Taylor	<3.0 ppb		<3.0 ppb									
	WF-7	1st floor by Stairwell #4	Water Fountain-Taylor	<3.0 ppb		<3.0 ppb									
	WF-8	1st floor by Stairwell #1 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-9	1st floor by Stairwell #1 - Upper	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-10	2nd floor by Stairwell #6 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-11	1st floor by Stairwell #6 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-12	2nd floor by Stairwell #1 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
WF-13	2nd floor Stairwell #4	Water Fountain-Taylor	<3.0 ppb		<3.0 ppb										
WF-14	3rd floor Stairwell #4	Water Fountain-Taylor	<3.0 ppb		<3.0 ppb										
WF-15	3rd floor Stairwell #1 - Lower	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb										
WF-16	3rd floor Stairwell #1 - Upper	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb										
PS25	SF-1	Kitchen Double Sink - Left	Sink Faucet	<3.0 ppb		5.4 ppb									
	SF-2	Kitchen Double Sink - Right	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-3	Nurse	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-4	2nd Floor Teachers Lounge	Sink Faucet	<3.0 ppb		<2.0 ppb									
	WF-1	2nd floor Michigan Side - Upper	Water Fountain-American Standard	<3.0 ppb		2.5 ppb									
	WF-2	2nd floor Michigan Side - Lower	Water Fountain-American Standard	<3.0 ppb		<2.0 ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	WF-3	2nd floor Illinois Side - Upper	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-4	2nd floor Illinois Side - Lower	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-5	1st floor Illinois Side - Upper	Water Fountain-American Standard	4.7 ppb		<2.0 ppb									
	WF-6	1st floor Illinois Side - Lower	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-7	1st floor Michigan Side Upper	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-8	1st floor Michigan Side Lower	Water Fountain-American Standard	3.0 ppb		2.3 ppb									
	WF-9	Ground floor Michigan Side - Upper	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-10	Ground floor Michigan Side - Lower	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-11	Ground floor Illinois Side - Upper	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
	WF-12	Ground floor Illinois Side - Lower	Water Fountain-American Standard	3.0 ppb		<2.0 ppb									
PS26															
	WF-1	Outside Room 114	Water Fountain-Elkay with cooler	3.0 ppb		<3.0ppb									
	WF-2	Outside Room 102	Water Fountain - no cooler	6.5ppb		5.5ppb									
	WF-3	Outside Room 202- Left larger upper	Water Fountain - no cooler	48 ppb		45ppb	94366	2.8 ppb FD, <2.0 ppb flush							
	WF-4	Outside 2nd fl Girls Bathroom Left Side	Water Fountain-Oasis w/cooler	4.3 ppb		<3.0ppb									
	WF-5	Outside 2nd fl Girls Bathroom Right Side	Water Fountain-Oasis w/cooler	3.0 ppb		<3.0ppb									
	WF-6	Outside Room B-7	Water Fountain-HRFS-no cooler	3.0 ppb		<3.0ppb									
	WF-7	Outside Gym	Water Fountain-HRFS-no cooler	3.0 ppb		<3.0ppb									
	WF-8	Inside Gym - Left Side	Water Fountain-Acorn w/cooler	3.0 ppb		<3.0ppb									
	WF-9	Inside Gym - Right Side	Water Fountain-Acorn w/cooler	3.0 ppb		<3.0ppb									
	WF-10	Trailer 9 Classroom	Water Fountain-AFTN-no cooler	3.0 ppb		Trailer was removed/ 2015-2016									
	WF-11	Classroom 111	Water Fountain	Out of Service	Out of Service this was not tested	110ppb	94365	6.3 FD, <2.0 ppb flush, 3rd test to confirm and verify <2.0 ppb							
	WF-12	Hot water outside room 202 - R smaller/lower	Water Fountain			27 ppb	94366	2.1 ppb							
	SF-1	Trailer 1 Classroom 1	Classroom Sink	3.0ppb		<3.0ppb									
	SF-2	Trailer 1 Classroom 2	Classroom Sink	3.0ppb		<3.0ppb									
	SF-3	Trailer 2 Classroom 1	Classroom Sink	3.0ppb		<3.0ppb									
	SF-4	Trailer 2 Classroom 2	Classroom Sink	3.0ppb		<3.0ppb									
	SF-5	Trailer 3 Classroom 1	Classroom Sink	3.0ppb		<3.0ppb									
	SF-6	Shared Nurse's office PS1/PS26	Sink Faucet	9.1 ppb		<3.0ppb							Shared nurses office with school PS1		
	SF-7	Trailer 3 Classroom 2	Classroom Sink	3.0ppb		4.4ppb									
	SF-8	Trailer 3 Classroom	Water Fountain	See Note		<3.0ppb							2014-2015 Not Sampled by lab		
	SF-9	Trailer 4 Classroom/Storage	Sink Faucet	N/A		<3.0ppb									
	SF-10	Kitchen	Sink Faucet	7.2 ppb		<3.0ppb									
	SF-11	Trailer 10 Classroom	Sink Faucet	<3.0 ppb		Trailer was removed/ 2015-2016									
	SF-12	Trailer 11 Classroom	Sink Faucet	<3.0 ppb		Trailer was removed/ 2015-2016									
	SF-13	Trailer 9 Classroom	Sink Faucet	3.0 ppb		Trailer was removed/ 2015-2016									
	SF-14	Trailer 4 Classroom/Storage	Sink Faucet	N/A		<3.0ppb									
	SF-15	room 202	Sink Faucet	N/A		1600 ppb*		are we retesting a nonpotable outlet or will signage be placed?					*This outlet was never used for potable water. Mr. Morlino requested it be tested as per the chief custodian.		
PS27															
	SF-1	Kitchen	Sink Faucet	3.0 ppb		<2.0 ppb									
	SF-2	Teachers Lounge 2NDFloor Main Bldg.	Sink Faucet	3.3 ppb		2.5 ppb									
	SF-3	Nurses Office	Sink Faucet	3.0 ppb		<2.0 ppb									
	WF-1	Basement near Custodial closet right	water fountain	out of service		out of service									
	WF-2	Basement near Custodial closet left	water fountain	out of service		out of service									
	WF-3	Cafeteria near bathrooms	Healey Taylor Water Fountain Bubblers	3.0 ppb		out of service									
	WF-4	Inside room 102	water fountain red	Out of service		2.6 ppb							no sample taken 2014-2015 low pressure		
	WF-5	outside new wing rm 107	water fountain stainless	Out of service		9.1 ppb							no sample taken 2014-2015 low pressure		
	WF-6	1st. Fl outside gym right	water fountain stainless	Out of service		2.0 ppb							no sample taken 2014-2015 low pressure		
	WF-7	1st. Fl outside gym center	water fountain red	Out of service		out of service							no sample taken 2014 & 2016 low pressure		
	WF-8	1st. Fl outside gym left	water fountain red	Out of service		2.4 ppb							no sample taken 2014-2015 low pressure		
	WF-9	1 st. fl room 133 Outside Girl's RR right	water fountain red	Out of service		out of service							no sample taken 2014 & 2016 low pressure		
	WF-10	1 st. fl room 133 Outside Girl's RR center	water fountain red	3.0 ppb		out of service							no sample taken 2014 & 2016 low pressure		
	WF-11	1 st. fl room 133 Outside Girl's RR left	water fountain red	Out of service		out of service							no sample taken 2014 & 2016 low pressure		
	WF-12	2nd fl Outside Rm 226, girl's rr Left	water fountain white	Out of service		11.0 ppb							no sample taken 2014-2015 low pressure		
	WF-13	2nd fl outside girl's RR rm 226 center red	water fountain red	3.5 ppb		5.5 ppb							no sample taken 2014-2015 low pressure		
	WF-14	2nd fl Girl's RR. rm 226 right	water fountain white	4.0 ppb		9.4 ppb									
	WF-15	2nd fl Outside Rm 216, boy's rr Right	water fountain stainless	3.0 ppb		<2.0 ppb							no sample taken 2014-2015 low pressure		
	WF-16	2nd fl Outside Rm 216, boy's rr center	water fountain white	Out of service		11 ppb							no sample taken 2014-2015 low pressure		
	WF-17	2nd fl Outside Rm 216, boy's rr left	water fountain white	Out of service		<2.0 ppb							no sample taken 2014-2015 low pressure		
	WF-18	Trailer A1	Stainless Steel Water Fountain	Out of service		Out of Service	to be provided by MM						Mechanical low pressure needs repair		
	WF-19	Trailer A2	Stainless Steel Water Fountain	<3.0ppb		<2.0 ppb									
	WF-20	Trailer B1	Stainless Steel Water Fountain	<3.0ppb		<2.0 ppb									
	WF-21	Trailer B2	Stainless Steel Water Fountain	3.0ppb		2.9 ppb									
PS28															
	SF-1	Kitchen-1st Floor-Left	Sink Faucet	1.7ppb		<3.0ppb									
	SF-2	Kitchen-1st Floor-Right	Sink Faucet	2.5ppb		<3.0ppb									
	SF-3	Nurses Office 1st Floor	Sink Faucet	330 ppb	<3.0ppb	86ppb	94601	140 ppb, 3rd sample 86 ppb*					This is used for hand washing only as confirmed by the Nurse. Tentative for retesting week of May 30th.		
	SF-4	Nurses Office 1st Floor by Closet	Sink Faucet	4.7 ppb		<3.0ppb									
	SF-5	Multi-Purpose Room	Sink Faucet	6.6 ppb		4.7ppb									
	SF-6	3rd Floor Room 314	Sink Faucet	15 ppb		<3.0ppb									
	SF-7	3rd Floor Room 313	Sink Faucet (Lab Sink)	24 ppb	<3.0 ppb	3.9ppb									
	SF-8	2nd Floor Room 208	Sink Faucet	6.3 ppb		<3.0ppb									
	WF-1	2nd Floor Hall outside Teachers Lounge - Right	Water Fountain-Ceramic	38 ppb	<3.0 ppb	<3.0ppb									
	WF-2	2nd Floor Hall outside Teachers Lounge - Left	Water Fountain-Stainless	39ppb	<3.0ppb	<3.0ppb									
	WF-3	1st Floor Lobby - Left	Water Fountain-Ceramic	4.0 ppb		Out of Service	94278	tentative week of May 30th.							
	WF-4	1st Floor Lobby - Right	Water Fountain-Ceramic	N/D		<3.0ppb									
	WF-5	Gym by Boys Locker Room- Left	Water Fountain-Ceramic	6.8 ppb		<3.0ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	WF-6	Gym by Boys Locker Room- Right	Water Fountain-Ceramic	Not Sampled		<3.0ppb									
	WF-7	Gym by Girls Locker Room - Left	Water Fountain-Ceramic			1.2 ppb									
	WF-8	Gym by Girls Locker Room-Right	Water Fountain-Ceramic	Not Sampled		<3.0ppb									
	WF-9	Cafeteria by Entrance - Right	Water Fountain-Ceramic			7.4 ppb									
	WF-10	Cafeteria by Entrance - Right	Water Fountain-Ceramic			15 ppb									
	WF-11	Cafeteria by Entrance - Left	Water Fountain-Ceramic			13 ppb									
	WF-12	Cafeteria by Entrance - Left	Water Fountain-Ceramic		30 ppb	32 ppb									
	WF-13	1st Floor Room 110	Water Fountain-Ceramic			5.2 ppb									
	WF-14	1st Floor Room 106	Water Fountain-Stainless			4.1 ppb									
	WF-15	1st Floor Room 105	Water Fountain-Stainless			8.2 ppb									
	WF-16	1st Floor Room 104	Water Fountain-Stainless			6.7 ppb									
	WF-17	1st Floor Room 103	Water Fountain-Stainless			13 ppb									
	WF-18	1st Floor Room 109	Water Fountain-Ceramic			2.8 ppb									
PS29															
	SF-1	Basement Cafeteria Kitchen	Sink Faucet		17 ppb	11 ppb									
	SF-2	Nurses Office B-3	Sink Faucet		9.9 ppb	8.5 ppb									
	SF-3	Teachers Lounge B-4	Sink Faucet		12 ppb	9.0 ppb									
	WF-1	Basement Cafeteria Boys Room Side	Water Fountain-Bubbler		4.5 ppb	4.8 ppb									
	WF-2	Basement Cafeteria Kitchen Side	Water Fountain-Bubbler		6.0 ppb	4.1 ppb									
	WF-3	1st Floor Hallway adjacent to Main Office	Water Fountain Cooler		<3.0 ppb	<3.0 ppb									
	WF-4	1st Floor Hallway adjacent to Main Office	Water Fountain -Bubbler-Elkay		6.6 ppb	3.9 ppb									
	WF-5	1st Floor Hallway by room 109	Water Fountain-Cooler		<3.0 ppb	<3.0 ppb									
	WF-6	1st Floor Hallway by room109	Water Fountain-Bubbler-Elkay		6.5 ppb	3.6 ppb									
	WF-7	2nd Floor Hallway by Room 212	Water Fountain Cooler		<3.0 ppb	<3.0 ppb									
	WF-8	2nd Floor Hallway by Room 212	Water Fountain Bubbler		3.5 ppb	<3.0 ppb									
	WF-9	2nd Floor Hallway by Room 211	Water Fountain Cooler		<3.0 ppb	<3.0 ppb									
	WF-10	2nd Floor Hallway by Room 211	Water Fountain Bubbler		3.3 ppb	<3.0 ppb									
PS30/MLK/RUTLAND															
	SF-1	KITCHEN SINGLE Sink	Sink Faucet		<3.0 ppb	4.2 ppb							16 ppb * see note	This is a handwashing sink. Signage?	
	SF-2	KITCHEN DOUBLE Sink RIGHT (actually triple)	Sink Faucet		<3.0 ppb	<2.0 ppb							15 ppb		
	SF-3	KITCHEN DOUBLE Sink LEFT (actually triple spray nozzle for dish washing)	Sink Faucet		5.1 ppb	tti TO VERIFY							9.0 ppb		
	SF-4	Kitchen Single Faucet double sink	Sink Faucet		N/A	69 ppb							verification needed.		
	SF-5	MAIN OFFICE WORK ROOM/KITCHEN	Sink Faucet		<3.0 ppb	<2.0 ppb									
	SF-6	2ND FL ROOM 207A TEACHER'S LOUNGE	Sink Faucet		<3.0 ppb	<2.0 ppb									
	SF-7	KINDERGARTEN TEACHER'S LOUNGE RIGHT	Sink Faucet		<3.0 ppb	<2.0 ppb									
	SF-8	KINDERGARTEN TEACHER'S LOUNGE LEFT	Sink Faucet		<3.0 ppb	11 ppb									
	SF-9	Nurse's office bathroom	Sink Faucet		N/A	4.7 ppb									
	SF-10	Nurse's Office waiting room	Sink Faucet		N/A	2.8 ppb									
	COMBO-1	ROOM 104 FOUNTAIN/SINK COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-2	ROOM 105 COMBO	Fountain/Sink		<3.0 ppb	14 ppb									
	COMBO-3	ROOM 109 COMBO	Fountain/Sink		4.6 ppb	2.3 ppb									
	COMBO-4	2ND FL ROOM 211 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-5	2ND FL ROOM 212 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-6	2ND FL ROOM 214 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-7	2ND FL ROOM 215 COMBO	Fountain/Sink		<3.0 ppb	10 ppb									
	COMBO-8	2ND FL ROOM 216 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-9	2ND FL ROOM 217 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-10	2ND FL ROOM 218 COMBO	Fountain/Sink		5.2 ppb	6.2 ppb									
	COMBO-11	2ND FL ROOM 219 COMBO	Fountain/Sink		<3.0 ppb	2.6 ppb									
	COMBO-12	2ND FL CORR. ADJ. RM 213 LEFT	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-13	3RD FL ROOM 304 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-14	3RD FL RM 303 COMBO	Fountain/Sink		<3.0 ppb	13 ppb									
	COMBO-15	3RD FL RM 302 COMBO	Fountain/Sink		<3.0 ppb	2.1 ppb									
	COMBO-16	3RD FL RM 310 COMBO	Fountain/Sink		<3.0 ppb	6.6 ppb									
	COMBO-17	3RD FL RM 311 COMBO	Fountain/Sink		6.4 ppb	4.9 ppb									
	COMBO-18	3RD FL RM 318 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-19	3RD FL RM 312 COMBO	Fountain/Sink		4.1 ppb	7.3 ppb									
	COMBO-20	3RD FL RM 313 COMBO	Fountain/Sink		3.2 ppb	7.8 ppb									
	COMBO-21	3RD FL RM 317 COMBO	Fountain/Sink		<3.0 ppb	4.0 ppb									
	COMBO-22	3RD FL RM 316 COMBO	Fountain/Sink		10.0 ppb	11 ppb									
	COMBO-23	3RD FL RM 314 COMBO	Fountain/Sink		<3.0 ppb	900 ppb	need work order								
	COMBO-24	3RD FL RM 315 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-25	ROOM 504 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-26	ROOM 505 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-27	ROOM 501 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-28	ROOM 502 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-29	ROOM 503 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-30	ROOM 506 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-31	ROOM 507 COMBO RUTLAND	Fountain/Sink		<3.0 ppb	<3.0 ppb									
	COMBO-32	CLASSROOM 402 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-33	CLASSROOM 401 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-34	CLASSROOM 403 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-35	CLASSROOM 405 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-36	CLASSROOM 404 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-37	CLASSROOM 406 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-38	CLASSROOM 407 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-39	CLASSROOM 409 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-40	CLASSROOM 408 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	COMBO-41	CLASSROOM 410 COMBO	Fountain/Sink		<3.0 ppb	<2.0 ppb									
	WF-1	1ST FL CORR. ADJ. RM 107	AM. STD. Water Fountain		<3.0 ppb	<2.0 ppb									
	WF-2	1ST FL CORR. ADJ. RM 106	AM. STD. Water Fountain		<3.0 ppb	<2.0 ppb									
	WF-3	1ST FL CORR. ADJ. TROPHY CABINET	AM. STD. Water Fountain		<3.0 ppb	<2.0 ppb									
	WF-4	GYM ADJ. G.L.R. RIGHT	AM. STD. Water Fountain		<3.0 ppb	<2.0 ppb									
	WF-5	GYM ADJ. B.L.R. LEFT	AM. STD. Water Fountain		<3.0 ppb	<2.0 ppb									
	WF-6	GYM ADJ. B.L.R. RIGHT	AM. STD. Water Fountain		<3.0 ppb	<2.0 ppb									

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	WF-7	1ST FL ADJ. SECURITY DESK	AM.STD. Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-8	3RD FL CORR. ADJ. RM 310 R	Water Fountain - Hasley Taylor	<3.0 ppb		8.6 ppb									
	WF-9	3RD FL CORR. ADJ. RM 310 LEFT	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-10	CORRIDOR ADJ. RIGHT SECURITY DESK	Water Fountain - Elkay	<3.0 ppb		<2.0 ppb									
	WF-11	CORRIDOR ADJ. LEFT SECURITY DESK	Water Fountain - Elkay	<3.0 ppb		<2.0 ppb									
AHA															
	WF-1	1st Floor by Restrooms Center	Water Fountain-Elkay WFR cooler	<3.0 ppb		<2.0 ppb									
	WF-2	1st Floor by Restrooms Right	Water Fountain-Elkay WFC cooler	<3.0 ppb		<2.0 ppb									
	WF-3	1st Floor by Restrooms Left	Water Fountain-Elkay WFL cooler	<3.0 ppb		<2.0 ppb									
	WF-4	2nd Floor by Restrooms	Water Fountain-Elkay WFR cooler	<3.0 ppb		<2.0 ppb									
	WF-5	2nd Floor by Restrooms	Water Fountain-Elkay WFC cooler	<3.0 ppb		<2.0 ppb									
	WF-6	2nd Floor by Restrooms	Water Fountain-Elkay WFL cooler	<3.0 ppb		<2.0 ppb									
	SF-1	Kitchen-Main	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-2	Kitchen Right	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-3	Nurse's Office	Sink Faucet	N/A		2.4 ppb									
ST. THERESE/STARS															
	SF-1	Kitchen Caf�-L	Sink Faucet	<3.0 ppb		4.3 ppb							Water was used prior to first draw		
	SF-2	Kitchen Caf�-R	Sink Faucet	6.1 ppb		6.3 ppb							Water was used prior to first draw		
	SF-3	Nurse bathroom	Sink Faucet	9.4 ppb		9.7 ppb									
	SF-4	Room 110 Conference room	Sink Faucet	21 ppb	3.8 ppb	21.0 ppb	95030/See Note						Non potable water- sink which serves bathroom Sink is located outside of the bathroom. Non potable signage posted		
	SF-5	Teacher lounge bathroom	Sink Faucet	4.3 ppb		13 ppb									
	SF-6	Small office by exit stairs	Sink Faucet	18 ppb		<3.0 ppb									
	WF-1	Next to Boys R-R 1st floor	Water Fountain	4.4 ppb		4.3 ppb									
	WF-2	Next to Girls R-R 1st floor	Water Fountain	4.3		Out of service	95030	tentative week of May 30th							
DALE															
	SF-1	Kitchen-Left Faucet	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-2	Kitchen-Left Faucet	Sink Faucet	<3.0 ppb		<2.0 ppb									
	WF-1	Gym 4th Floor	Water Fountain	8.8 ppb		9.5 ppb	95135	tentative week of May 30th							
	WF-2	Hall across from 414	Water Fountain	3.1 ppb		<2.0 ppb									
	WF-3	Hall across from 305	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-4	Hallway across from Room 312-Right WF	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-5	Hallway across from Room 312-Left WF	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-6	Hallway next to Room 211	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-7	Across from Kitchen	Water Fountain	4.1 ppb		<2.0									
		Teacher's Lounge	N/S	N/S		N/S									
		Nurse's office Water Cooler in use	Sink Faucet- Bathroom			Water Cooler in use									
DON BOSCO															
	SF-1	Kitchen along wall	Sink Faucet	<3.0ppb		<2.0 ppb									
	SF-2	Kitchen Center	Sink Faucet	<3.0 ppb		2.7 ppb									
	SF-3	Nurses Office	Sink Faucet	7.6ppb		5.3 ppb									
	SF-4	Teachers Lounge	Sink Faucet	5.0ppb		6.3 ppb									
	WF-1	Cafeteria- left side	Water Fountain-Stainless	13ppb		540 ppb	95379	tentative week May 30th							
	WF-2	Cafeteria- right side	Water Fountain-Ceramic	Removed/See Note	Removed/See Note	removed/ see note	84218						Building scheduled to be demo July 2016		
	WF-3	1st Floor Hallway next to 107-left	Water Fountain-stainless	<3.0 ppb		<2.0 ppb									
	WF-4	1st Floor Hallway next to 107	Water Fountain-Ceramic	<3.0 ppb		<2.0 ppb									
	WF-5	2nd Floor Hallway adjacent to Main Office	Water Fountain-Ceramic	Out of Service/See Note	Out of Service/See Note	16 ppb	95378	tentative week May 30th					Building scheduled to be demo July 2016		
	WF-6	3rd Floor Hallway next to Boys Restroom-left	Water Fountain-Ceramic	<3.0ppb		<2.0 ppb									
	WF-7	3rd Floor Hallway next to Boys Restroom-right	Water Fountain-Ceramic	Out of Service/See Note	Out of Service/See Note	<2.0 ppb							Building scheduled to be demo July 2016		
	WF-8	3rd Floor Hallway next to Girls Restroom-left	Water Fountain-Ceramic	<3.0ppb		<2.0 ppb									
	WF-9	3rd Floor Hallway next to Girls Restroom-right	Water Fountain-Ceramic	<3.0ppb		<2.0 ppb									
	WF-10	2nd Floor Hall next to room 207	Water Fountain-Stainless			<2.0 ppb									
ELC															
	SF-1	Kitchen - Right Faucet	Sink Faucet	2.6 ppb		2.1 ppb									
	SF-2	Nurse's Office	Sink Faucet	N/A		N/A							There is no sink according to the chief.		
	WF-1	Room 4	Water Fountain	N/D		<2.0 ppb									
	WF-2	Room 5	Water Fountain	N/D		<2.0 ppb									
	WF-3	Room 6	Water Fountain	N/D		<2.0 ppb									
	WF-4	Room 3	Water Fountain	N/D		<2.0 ppb									
	WF-5	Room 2	Water Fountain	N/D		<2.0 ppb									
	WF-6	Room 1	Water Fountain	N/D		<2.0 ppb									
	WF-7	Hallway outside Room 3	Water Fountain	9.2 ppb		4.5 ppb									
ESH															
		TEMP. CLASSROOM UNITS													
	SF-1	E-17 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-2	E-17 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-3	E-18 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-4	E-18 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-5	E-13 Restroom/D13 ???	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-6	E-13 Classroom/D13???	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-7	D-14 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-8	D-14 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-9	D-15 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-10	D-15 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-11	D-16 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-12	D-16 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-13	C-9 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-14	C-9 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-15	C-10 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-16	C-10 Classroom	Sink Faucet	<3.0 ppb		<2.0 ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	SF-17	C-11 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-18	C-11 Classroom	Sink Faucet	<3.0 ppb		2.3 ppb									
	SF-19	C-12 Restroom	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-20	C-12 Classroom	Sink Faucet	<3.0 ppb		2.1 ppb									
	WF-1	E-17	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-2	E-18	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-3	E-13/D13 ????	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-4	D-14	Water Fountain-Elkay	<3.0pppb		2.2 ppb									
	WF-5	D-15	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-6	D-16	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-7	C-9	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-8	C-10	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-9	C-11	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
	WF-10	C-12	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
		MAIN BUILDING													
	SF-1	Kitchen lower level IN FRONT OF OVEN	Sink Faucet	<3.0 ppb											
	SF-2	Kitchen lower level BACK WALL LEFT	Sink Faucet	3.7 ppb		3.0 ppb									
	SF-3	Kitchen lower level BACK WALL RIGHT	Sink Faucet	<3.0 ppb		2.7 ppb									
	SF-4	Kitchen lower level BACK WALL MIDDLE	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-5	Kitchen lower level NEXT TO FREEZER L	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-6	Kitchen lower level NEXT TO FREEZER R	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-7	Kitchen lower level NEXT TO MICROWAVE	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-8	Kitchen lower level BY HOT BOX SMALL	Sink Faucet	<3.0 ppb		3.4 ppb									
	SF-9	Kitchen lower level BY HOT BOX LARGE	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-10	1ST FLOOR KITCHEN NEXT TO Ref-L	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-11	1ST FLOOR KITCHEN NEXT TO Ref-R	Sink Faucet	<3.0 ppb		3.5 ppb									
	SF-12	1ST FLOOR KITCHEN BEHIND SERVICE COUNTER LARGE	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-13	1ST FLOOR KITCHEN BEHIND SERVICE COUNTER SMALL	Sink Faucet	74 ppb		10 ppb	95006								
	SF-14	1ST FLOOR CAFE UNDER WINDOW SMALL	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-15	1ST FLOOR CAFE UNDER WINDOW LARGE	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-16	1ST FLOOR RM 107 BY DISH WASHER	Sink Faucet	<3.0 ppb		3.1 ppb									
	SF-17	1ST FL RM 107 BY DISH WASHER BY OPPOSITE DISH WASHER	Sink Faucet	<3.0 ppb		5.6 ppb									
	SF-18	1ST FL RM 107 UNDER WINDOW L	Sink Faucet	15 ppb		<2.0 ppb									
	SF-19	1 FL RM 107 UNDER WINDOW R	Sink Faucet	6.6 ppb		<2.0 ppb									
	SF-20	Nurse's Office	Sink Faucet	N/A		<2.0 ppb									
	SF-21	Nurse's Office	Sink Faucet	N/A		<2.0 ppb									
	SF-22	Teacher's Lounge rm 215	Sink Faucet	N/A		<2.0 ppb									
	SF-23	Gym Ford's Office Bathroom	Sink Faucet	N/A		<2.0 ppb									
	SF-24	Gym Ford's Office	Sink Faucet	N/A		<2.0 ppb									
	SF-25	Adam's office in gym	Sink Faucet	N/A		<2.0 ppb									
	WF-1	3RD FL ACROSS FROM RM 300 L	Water Fountain	<3.0 ppb		5.5 ppb									
	WF-2	3RD FL ACROSS FROM RM 300 R	Water Fountain	<3.0 ppb		5.7 ppb									
	WF-3	3RD FL ACROSS FROM RM 322	Water Fountain	9.2 ppb											
	WF-4	3RD FL ACROSS FROM RM 315 L	Water Fountain	42 ppb		3.0 ppb	87060								
	WF-5	3RD FL ACROSS FROM RM 315 R	Water Fountain	10 ppb		2.4 ppb									
	WF-6	3RD FL ACROSS FROM RM 307-L	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-7	1ST FL CAFE ADJACENT TO DOOR 18	Water Fountain	5.1 ppb											
	WF-8	1ST FL CAFE ADJACENT TO DOOR 19	Water Fountain	<3.0 ppb		2.2 ppb									
	WF-9	1ST FL HW ADJACENT TO STAIR 13	Water Fountain	<3.0 ppb		4.3 ppb									
	WF-10	1ST FL HW ADJACENT TO STAIR 1	Water Fountain	10 ppb		<2.0 ppb									
	WF-11	1ST FL HW ADJACENT TO RM 102	Water Fountain	3.0 ppb		6.1 ppb									
	WF-12	1ST FL HW ADJACENT TO RM 113	Water Fountain	13 ppb											
	WF-13	1ST FL HW ADJACENT TO RM 118 R	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-14	1ST FL HW ADJACENT TO RM 118L	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-15	1ST FL HW ADJACENT TO RM 107	Water Fountain	6.7 ppb		14 ppb									
	WF-16	2ND FL HW ADJACENT TO RM 207	Water Fountain	57 ppb		<2.0 ppb	87066								
	WF-17	2ND FL HW ADJACENT TO RM 203	Water Fountain	5.7 ppb		26 ppb									
	WF-18	2ND FL HW ADJACENT TO STAIR 1	Water Fountain	7.4 ppb											
	WF-19	2ND FL HW ADJACENT TO RM 241a	Water Fountain	4.9 ppb											
	WF-20	2ND FL HW ADJACENT TO RM 236	Water Fountain	62 ppb			87062/See Note								
	WF-21	BASEMENT HW ADJACENT TO RM 10	Water Fountain	<3.0 ppb		<2.0 ppb							Unit removed/Waiting for replacement		
	WF-22	BASEMENT HW ADJACENT TO RM 02	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-23	BOYS LOCKER RM ADJACENT TO COACH OFFICE	Water Fountain	<3.0 ppb		<2.0 ppb									
	WF-24	BASEMENT HW ADJACENT TO STAIR 13	Water Fountain	<3.0 ppb		18 ppb									
	WF-25	BASEMENT HW ADJACENT TO RM 45	Water Fountain	68 ppb		<2.0 ppb	87069								
	WF-26	Girl's Locker Room near G-2	Water Fountain	N/A		27 ppb									
	WF-27	2nd Fl Corridor adl. 207	Water Fountain	N/A		<3.0 ppb									
	WF-28	opposite rm 128	Water Fountain	N/A		47 ppb									
	WF-29	Basement outside of woodshop	Water Fountain	N/A		N/A see note							Parts missing not tested		
		ST. PAULS/STRIVE													
	SF-1	Kitchen	Sink Faucet	<3.0 ppb		2.2 ppb									
	SF-2	Nurse's Office	Sink Faucet	n/a		5.5 ppb									
	SF-3	Teacher's Lounge(s)/conference rm	Sink Faucet	n/a		46 ppb	need work order								
	WF-1	Cafeteria Adjacent to Security Desk	Water Fountain-Elkay non cooler	<3.0pppb		<2.0 ppb									
	WF-2	2nd Floor Hallway	Water Fountain-Elkay	<3.0pppb		<2.0 ppb									
							Relocated to Colt St. 1/4/16								
		MALL													
	SF-1	Nurse Office Restroom	Sink Faucet	<3.0 ppb											
	WF-1	Kitchen next to Warmer	Water Fountain	<3.0 ppb											
	WF-2	Kitchen next to larger Sink	Water Fountain	11 ppb											
	WF-3	Kitchen Back Wall	Water Fountain	<3.0 ppb											
	WF-4	Room 351	Water Fountain	<3.0 ppb											
	WF-5	Room 350	Water Fountain	<3.0 ppb											
	WF-6	Main Office next to Ladies Restroom	Water Fountain	<3.0pppb											
	WF-7	Main Office next to Men's Restroom	Water Fountain	<3.0pppb											

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
INTERNATIONAL															
	SF-1	Kitchen by slicer	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-2	Kitchen, near fire extinguisher	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-3	Kitchen by dishwashing -L #30	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-4	Kitchen by dishwashing-R # 30	Sink Faucet	<3.0 ppb		4.95 ppb									
	SF-5	Kitchen near freezer #23	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-6	Kitchen next to exit door 21	Sink Faucet	11 ppb		<3.0 ppb									
	SF-7	Kitchen next to exit door 22	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-8	Faculty Room 24	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-9	Home Econ -L 210	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-10	Home Econ -R 210	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-11	Nurse #26	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-12	3rd Floor Faculty Room 311 #27	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-13	4th Floor Faculty Room 411	Sink Faucet	<3.0 ppb		<3.0 ppb									
	WF-1	4th Floor #17	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-2	4th Floor # 19	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-3	4th Floor # 19	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-4	4th Floor next to Girl's RR rm 417 # 20	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-5	3rd Floor #13	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-6	3rd Floor #14	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-7	3rd Floor #15	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-8	3rd Floor 16	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-9	2nd Floor #7	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-10	2nd Floor #8	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-11	2nd Floor Cafeteria #9 right	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-12	2nd Floor Cafeteria #10 left	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-13	2nd Floor #11	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-14	2nd Floor #12	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-15	1st Floor #5	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-16	1st Floor #6	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-17	1st Floor #1	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-18	1st Floor #2	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-19	1st Floor #3	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
	WF-20	1st Floor #4	Water Fountain / Water Cooler	<3.0 ppb		<3.0 ppb									
IFK															
	SF-1	Kitchen-Double Sink-Left	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-2	Kitchen-Double Sink-Right	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-3	Kitchen by Microwave	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-4	Kitchen next to Fridge	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-5	Kitchen Room next to Freezer	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-6	Kitchen North Facing Breakness	Sink Faucet SS	N/A		4.5 ppb									
	SF-7	Kitchen South Side of SS Prep Table	Sink Faucet	N/A		<2.0 ppb									
	SF-8	Cafeteria B	Sink Faucet porcelain	N/A		<2.0 ppb									
	SF-9	Cafeteria B	Sink Faucet SS	N/A		<2.0 ppb									
	SF-10	Cafeteria A, near Refrigerator East	Sink Faucet SS	N/A		<2.0 ppb									
	SF-11	Cafeteria A, near Refrigerator West	Sink Faucet SS	N/A		2.3 ppb									
	SF-12	Cafeteria A Old Store	Sink Faucet SS	N/A		4.8 ppb									
	SF-13	Nurse Metal Sink	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-14	Nurse Rest Room	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-15	Westside Caf	Sink Faucet SS	N/A		<2.0 ppb									
	SF-16	Westside Caf	Sink Faucet ceramic	<3.0 ppb		<2.0 ppb									
	SF-17	Room 320 Home Economics	Sink Faucet	<3.0 ppb		2.3 ppb									
	SF-18	Behind Service Line Kitchen	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-19	Room 346 rear classroom	sink	N/A		15 ppb	96134								
	SF-20	Room 346 prep room	sink	N/A		5.2 ppb									
	SF-21	Room 347 rear classroom	sink	N/A		33 ppb	96135								
	SF-22	Room 347 prep room	sink	N/A		15 ppb	96136								
	SF-23	Room 348 rear classroom	sink	N/A		6.0 ppb									
	SF-24	Room 351 rear of classroom	sink	N/A		9.1 ppb									
	SF-25	Room 351 prep room	sink # 1	N/A		940 ppb	96137								
	SF-26	Room 351 prep room	sink # 2	N/A		8.1 ppb									
	SF-27	Room 352, right	sink	N/A		13 ppb									
	SF-28	Room 352, left	sink	N/A		10 ppb									
	SF-29	Room 251 left side rear	sink	N/A		<2.0 ppb									
	SF-30	Room 251 right side rear	sink	N/A		<2.0 ppb									
	SF-31	Room 251 prep room	sink	N/A		210 ppb	96138								
	SF-32	Room 251 storage room	sink	N/A		13 ppb									
	SF-33	Room 252 left side	sink	N/A		9.6 ppb									
	SF-34	Room 252 right side	sink	N/A		2.4 ppb									
	SF-35	Room 252 prep room #1	sink	N/A		<2.0 ppb									
	SF-36	Room 252 prep room #2	sink	N/A		out of order									
	SF-37	Room 251 prep room right	sink	N/A		4.5 ppb									
	SF-38	Room 231 prep room left	sink	N/A		34 ppb	96139								
	WF-1	Next to Room 321	Fountain-no cooler-ceramic H.T.	<3.0 ppb		2.3 ppb									
	WF-2	Next to Service Closet	Fountain-no cooler-Stainless	<3.0 ppb		<2.0 ppb									
	WF-3	Across from Room 328	Fountain-no cooler-ceramic H.T.	3.8 ppb		8.0 ppb									
	WF-4	Across from Room 336	Fountain-no cooler-ceramic H.T.	<3.0 ppb		2.1 ppb									
	WF-5	Hallway across from room 340	Fountain	N/A		5.5 ppb									
	WF-6	Hallway Outside Stem 344-354	Fountain-no cooler-ceramic H.T.	<3.0 ppb		2.3 ppb									
	WF-7	Across from Room 348	Fountain-no cooler-ceramic H.T.	<3.0 ppb		<2.0 ppb									
	WF-8	Hallway near exit 6, 3rd floor	Fountain	N/A		8.2 ppb									
	WF-9	Across from Room 312	Fountain-no cooler-ceramic H.T.	<3.0 ppb		<2.0 ppb									
	WF-10	Hallway across from room 309	Fountain	N/A		3.8 ppb									
	WF-11	Across from Room 255	Fountain-no cooler-ceramic H.T.	<3.0 ppb		2.8 ppb									
	WF-12	Across from Room 248	Fountain-no cooler-ceramic H.T.	<3.0 ppb		3.1 ppb									
	WF-13	Across from Room 250	Fountain-no cooler-ceramic H.T.	5.1 ppb		19 ppb	96140								

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	WF-14	Across from room 209	Fountain	N/A		<2.0 ppb									
	WF-15	Hallway across from 217	Fountain	N/A		5.5 ppb									
	WF-16	Hallway across from 214	Fountain	N/A		2.6 ppb									
	WF-17	Hallway across from 240	Fountain	N/A		3.9 ppb									
	WF-18	To Right Wall off Library	Fountain-no cooler-stainless	<3.0 ppb		<2.0 ppb									
	WF-19	Across from Room 236A	Fountain-no cooler-stainless	<3.0 ppb		<2.0 ppb									
	WF-20	1st Floor next to Principal (General Office)	Water Fountain-Halsey Taylor	<3.0 ppb		2.6 ppb									
	WF-21	Across from Security 1st Floor	Water Fountain-Halsey Taylor	<3.0 ppb		<2.0 ppb									
	WF-22	Hallway across from 107	Fountain	N/A		2.2 ppb									
	WF-23	Hallway across from counselor's office	Fountain	N/A		2.3 ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	WF-24	1st Floor next to Room 112 BTMF	Water Fountain-Halsey Taylor	<3.0 ppb		<2.0 ppb									
	WF-25	Outside Auditorium Right of Stage	Water Fountain-Halsey Taylor	<3.0 ppb		18 ppb	96141								
	WF-26	Hallway outside Custodial Office	Water Fountain			out of order	96142								
	WF-27	Next to Room 117 1st Floor	Water Fountain-Halsey Taylor	<2 ppb		5.7 ppb									
	WF-28	Wood Shop 117 1st Floor	Water Fountain-Halsey Taylor	<3.0 ppb		<2.0 ppb									
	WF-29	Front Entrance to Gym Boys Restroom Side	Water Fountain-Stainless	<3.0 ppb											
	WF-30	Front Entrance to Gym Girls Restroom Side	Water Fountain-Stainless	<3.0 ppb		3.7 ppb									
	WF-31	Boys Locker Room 1st Floor	Water Fountain-Taylor	<3.0 ppb		2.1 ppb									
	WF-32	Girls Locker Room 1st Floor	Water Fountain-Taylor	<3.0 ppb		<2.0 ppb									
	WF-33	Coach's office front room	Water Fountain	N/A		<2.0 ppb									
	WF-34	Basement near Auto shop	Water Fountain	N/A		6.2 ppb									
IFX TRAILERS															
		Temp. Classroom Unit													
	WF-1	Trailer B-8	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
	WF-2	Trailer B-7	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
	WF-3	Trailer B-6	Water Fountain-Stainless	<3.0 ppb		2.4 ppb									
	WF-4	Trailer B-5	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
	WF-5	Trailer B-4	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
	WF-6	Trailer B-3	Water Fountain-Stainless	<3.0 ppb		N/A									
	WF-7	Trailer A-2	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
	WF-8	Trailer A-1	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
	WF-9	Trailer A-4	Water Fountain	N/A		<2.0 ppb									
	WF-10	Trailer A-3	Water fountain	N/A		<2.0 ppb									
	SF-1	Trailer B6 Sink behind breaker panel	sink	N/A		2.8 ppb									
	SF-2	Trailer B5 Sink behind breaker panel	sink	N/A		<2.0 ppb									
	SF-3	Trailer B8 Sink behind breaker panel	sink	N/A		3.9 ppb									
	SF-4	Trailer B7 Sink behind breaker panel	sink	N/A		<2.0 ppb									
	SF-5	Trailer A4 Sink behind breaker panel	sink	N/A		<2.0 ppb									
	SF-6	Trailer A3 sink behind breaker panel	sink	N/A		<2.0 ppb									
	SF-7	Trailer A1 sink behind breaker panel	sink	N/A		4.1 ppb									
	SF-8	Trailer A2 sink behind breaker panel	sink	N/A		<2.0 ppb									
EWK															
	SF-1	Kitchen Double Sink-Right (triple)	Sink Faucet	8.3 ppb		13ppb									
	SF-2	Kitchen Double Sink-Left (triple)	Sink Faucet	<3.0 ppb		3.6ppb									
	SF-3	Kitchen Single Sink	Sink Faucet	<3.0 ppb		<3.0ppb									
	SF-4	NURSE'S OFFICE	Sink Faucet	N/A		water cooler in use									
	SF-5	TEACHER'S LOUNGE(S)	Sink Faucet	N/A		water cooler in use									
	SF-5	Main office sink- non potable	Sink Faucet	N/A		NON POTABLE									
	SF-6	Library office	Sink Faucet	N/A		NON POTABLE									
	SF-7	Room 107	SLOP SINK	N/A		NON POTABLE									
		Room 307 - 3 double sinks but only 1 st double sink is in use --non potable. Other 2 are inoperable.	1 double sink	N/A		NON POTABLE									
	SF-8	Upper sink adjacent to room 103	Sink Faucet	N/A		NON POTABLE									
	WF-1	Basement next to boys room-upper	Water Fountain-Elkay	3.4ppb		<3.0ppb									
	WF-2	Basement next to boys room-lower	Water Fountain-American	<3.0ppb		<3.0ppb									
	WF-3	1st adjacent to 103	Water Fountain-Halsey Taylor	<3.0ppb		Out of Service	94597	FD 5.7 ppb, Flush <2.0 ppb							
	WF-4	1st Floor 101	Water Fountain	<3.0 ppb		4.7ppb									
	WF-5	1st Floor 102	Water Fountain	<3.0 ppb		<3.0ppb									
	WF-6	1st Floor 103	Water Fountain	3.4 ppb		Out of Service	94305	tentative week of May 30th							
	WF-7	2nd Floor 202	Water Fountain	15 ppb		7.4ppb	94306								
	WF-8	2nd Floor 200	Water Fountain	2.6 ppb		<3.0ppb									
	WF-9	2nd Floor adjacent to Room 202-Upper	Water Fountain-American	120ppb	N/D	<3.0ppb									
	WF-10	2nd Floor adjacent to Room 202- Lower	Water Fountain-Halsey Taylor	<3.0ppb		<3.0ppb									
	WF-11	3rd Floor adjacent to Stair 3B Upper	Water Fountain-American	<3.0ppb		9.8ppb									
	WF-12	3rd Floor adjacent to Stair 3B Lower	Water Fountain-American	<3.0ppb		<3.0ppb									
	Combo-1	Room 203 sink and water fountain combo	Sink Faucet/water fountain	N/A		Out of Service	repaired	tentative week of May 30th							
	Combo-2	Room 202 sink and water fountain combo	Sink Faucet/water fountain	N/A		Out of Service	repaired	tentative week of May 30th							
	Combo-3	room 103 sink and water fountain combo	Sink Faucet/water fountain	N/A		out of Service	repaired	tentative week of May 30th							
MADISON ELC															
	SF-1	Kitchen	Double Sink-Right	<3.0 ppb		<3.0ppb									
	SF-2	Kitchen	Double Sink-Left	<3.0 ppb		<3.0ppb									
	SF-3	Teachers Room	Sink Faucet	<3.0 ppb		<3.0ppb									
	SF-4	Nurses Office	Sink Faucet	29 ppb		<3.0ppb									
	WF-1	Classroom 101	Water Fountain	<3.0 ppb		<3.0ppb									
	WF-2	Classroom 103	Water Fountain	<3.0 ppb		<3.0ppb									
	WF-3	Classroom 105	Water Fountain	<3.0 ppb		<3.0ppb									
	WF-4	Classroom 107	Water Fountain	<3.0 ppb		<3.0ppb									
	WF-5	Hallway adjacent to Classroom 103	Water Fountain	<3.0 ppb		<3.0ppb									
NRC															
	SF-1	Kitchen	Triple Sink-left faucet	<3.0 ppb		<2.0 ppb									
	SF-2	Kitchen	Triple Sink-right faucet	<3.0 ppb		<2.0 ppb									
	SF-3	Kitchen near	Double Sink	<3.0 ppb		<2.0 ppb									
	SF-4	Kitchen	Single Sink	<3.0 ppb		<2.0 ppb									
	SF-5	Kitchen Serving Area	Single Sink	<3.0 ppb		<2.0 ppb									
	SF-6	Faculty Dining	Single Sink	<3.0 ppb		<2.0 ppb									
	SF-7	Community Center 1B33	Single Sink	<3.0 ppb		<2.0 ppb									
	SF-8	Room 1B08	Single Sink	<3.0 ppb		<2.0 ppb							PAARC no access and sampled later date. COC and lab results identify as 1D instead of 1B. There is no 1D.		
	SF-9	ROOM 2B20 computer room	Sink faucet	N/A		<2.0 ppb									
	SF-10	Room 2B17 on wall near dishwasher (Art Rm 1)	Sink faucet	N/A		5.1 ppb									
	SF-11	Room 2B17 Oak St. side (Art Rm 1)	Sink faucet	N/A		<2.0 ppb									
	SF-12	Room 2B17 E19th St. (Art Rm 1)	Sink faucet	N/A		<2.0 ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	SF-13	Room 2B17 Market St. (art Rm 1)	Sink faucet	N/A		<2.0 ppb									
	SF-14	Room 2B14 Left (art room 2)	Sink faucet	N/A		<2.0 ppb									
	SF-15	Room 2B14 Right (art room 2)	Sink faucet	N/A		<2.0 ppb									
	SF-16	2B11 Computer Room	Sink faucet	N/A		<2.0 ppb									
	SF-17	1B28 work rm off library	Sink faucet	N/A		<2.0 ppb									
	SF-18	1A229	Sink faucet	N/A		<2.0 ppb									
	SF-19	1A219	Sink faucet	N/A		<2.0 ppb									
	SF-20	1A224	Sink faucet	N/A		<2.0 ppb									
	SF-21	2A126	Sink faucet	N/A		<2.0 ppb									
	SF-22	2A118	Sink faucet	N/A		<2.0 ppb									
	SF-23	2A116	Sink faucet	N/A		<2.0 ppb									
	SF-24	2A114	Sink faucet	N/A		<2.0 ppb									
	SF-25	2A112	Sink faucet	N/A		<2.0 ppb									
	SF-26	2A101	Sink faucet	N/A		2.2 ppb									
	SF-27	2A103	Sink faucet	N/A		<2.0 ppb									
	SF-28	2A105	Sink faucet	N/A		<2.0 ppb									
	SF-29	2A107	Sink faucet	N/A		<2.0 ppb									
	SF-30	2A109	Sink faucet	N/A		<2.0 ppb									
	SF-31	2A202	Sink faucet	N/A		<2.0 ppb									
	SF-32	2A204	Sink faucet	N/A		<2.0 ppb									
	SF-33	2A208	Sink faucet	N/A		2.3 ppb									
	SF-34	2A210	Sink faucet	N/A		<2.0 ppb									
	SF-35	2A212	Sink faucet	N/A		<2.0 ppb									
	SF-36	2A226	Sink faucet	N/A		<2.0 ppb									
	SF-37	2A224	Sink faucet	N/A		<2.0 ppb									
	SF-38	2A222	Sink faucet	N/A		<2.0 ppb									
	SF-39	2A219	Sink faucet	N/A		<2.0 ppb									
	SF-40	2A217	Sink faucet	N/A		<2.0 ppb									
	SF-41	2A126	Sink faucet	N/A		<2.0 ppb									
	SF-42	1A120	Sink faucet	N/A		<2.0 ppb									
	SF-43	1A235	Sink faucet	N/A		<2.0 ppb									
	SF-44	1A101	Sink faucet	N/A		<2.0 ppb									
	SF-45	1A103	Sink faucet	N/A		<2.0 ppb									
	SF-46	1A105	Sink faucet	N/A		<2.0 ppb									
	SF-47	1A107	Sink faucet	N/A		<2.0 ppb									
	SF-48	1A109	Sink faucet	N/A		<2.0 ppb									
	SF-49	1A202	Sink faucet	N/A		<2.0 ppb									
	SF-50	1A204	Sink faucet	N/A		<2.0 ppb									
	SF-51	1A217	Sink faucet	N/A		<2.0 ppb									
	SF-52	1A208	Sink faucet	N/A		<2.0 ppb									
	SF-53	1A210	Sink faucet	N/A		<2.0 ppb									
	SF-54	1A212	Sink faucet	N/A		<2.0 ppb									
	SF-55	Kitchen by large hot box	Sink faucet	N/A		<2.0 ppb									
	SF-56	Kitchen by convection steamer (small)	Sink faucet	N/A		<2.0 ppb									
	WF-1	Gym upper	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-2	Gym lower	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-3	Boys Locker Room & RR	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-4	Girls Locker Room & RR	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-5	Room 1A219	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-6	Room 1A 224	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									
	WF-7	Room 1A229	Water Fountain-Elkay	<3.0 ppb		<2.0 ppb									

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	WF-8	1A Girls Room lower	Water Fountain-Elkay-left	<3.0 ppb		<2.0 ppb									
	WF-9	1A Girls Room upper	Water Fountain-Elkay-right	<3.0 ppb		<2.0 ppb									
	WF-10	1A Boys Room upper	Water Fountain-Elkay-left	<3.0 ppb		<2.0 ppb									
	WF-11	1A Boys Room lower	Water Fountain-Elkay-right	<3.0 ppb		<2.0 ppb									
	WF-12	Across from Room 1B31	Water Fountain-Upper left	<3.0 ppb		<2.0 ppb									
	WF-13	Across from Room 1B31	Water Fountain-Upper right	N/D		<2.0 ppb									
	WF-14	Across from Room 1B31	Water Fountain-Lower left	N/D		<2.0 ppb									
	WF-15	Across from Room 1B31	Water Fountain-Upper right	N/D		<2.0 ppb									
	WF-16	2A Boys RR lower	Water Fountain-Left	N/D		<2.0 ppb									
	WF-17	2A Boys Room upper	Water Fountain-Right	N/D		<2.0 ppb									
	WF-18	2A Girls RR upper	Water Fountain-Left	N/D		<2.0 ppb									
	WF-19	2A Girls Room lower	Water Fountain-Right	N/D		<2.0 ppb									
	WF-20	Hallway Across 2B11 center	Water Fountain-lower right	N/D		<2.0 ppb									
	WF-21	Hallway Across 2B11 center	Water Fountain-upper left	N/D		out of order	91864	awaiting repairs							
	WF-22	Hallway Across 2B11 far right	Water Fountain-lower right	N/D		<2.0 ppb									
	WF-23	Hallway Across 2B11 far left	Water Fountain-Upper left	N/D		<2.0 ppb									
NORMAN S. WEIR															
	SF-1	Kitchen-Left	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-2	Kitchen-Center	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-3	Kitchen-Right	Sink Faucet	<3.0 ppb		4.6 ppb									
	SF-4	Nurse office	Sink Faucet	N/A		<2.0 ppb									
	SF-5	Teacher Lounge	Sink Faucet	N/A		<2.0 ppb									
	WF-1	Lobby left	FountainCooler-Left	<3.0 ppb		<3.0 ppb									
	WF-2	Lobby right	Fountain Cooler-Right	<3.0 ppb		<3.0 ppb									
	WF-3	Basement	Fountain Cooler	<3.0 ppb		<3.0 ppb									
	WF-4	2nd Floor Hallway	Fountain Cooler-Left	<3.0 ppb		<3.0 ppb									
	WF-5	2nd Floor Hallway	Fountain Cooler-Right	<3.0 ppb		<3.0 ppb									
	WF-6	3rd Floor Hallway	Fountain Cooler	<3.0 ppb		<3.0 ppb									
PANTHER															
	WF-1	1st Floor adjacent to Room 129	Water Fountain-Chiller-Elkay	<3.0 ppb		<2.0 ppb									
	WF-2	2nd Floor adjacent to Boys Bathroom	Water Fountain-Elkan non Chiller	<3.0ppb		<2.0 ppb									
	SF-1	1st Floor Teachers Lounge Room 119	Sink Faucet	<3.0ppb		<2.0 ppb									
	SF-2	Nurse's office	sink Faucet	N/A		<2.0 ppb									
		Kitchen	No Kitchen	No Kitchen		No Kitchen									
ROBERTO CLEMENTE															
	SF-1	Kitchen-Single next to Stove	Sink Faucet	<3.0 ppb		2.3 ppb									
	SF-2	Kitchen Double Sink - Left	Sink Faucet	3.3 ppb		4.1 ppb									
	SF-3	Kitchen Double Sink - Right	Sink Faucet	3.2 ppb		4.9 ppb									
	SF-4	Kitchen - Single Alone	Sink Faucet	<3.0 ppb		6.2 ppb									
	SF-5	1st Floor Teachers Lounge	Sink Faucet	<3.0 ppb		<2.0 ppb									
	SF-6	Nurse's office	Sink Faucet	N/A		2.1 ppb									
	SF-7	Kitchen single next to slicer and refrigerators	Sink Faucet	N/A		<2.0 ppb									
	WF-1	Basement near Chiefs Office	Water Fountain-Porcelain	3.3ppb		6.0 ppb									
	WF-2	Basement near 1A	Water Fountain-Elkay	<3.0ppb		<2.0 ppb									
	WF-3	1st Floor adjacent to Gym	Water Fountain-Halsey Taylor	<3.0 ppb		<2.0 ppb									
	WF-4	1st Floor Classroom 2 Wall Mounted	Water Fountain-Porcelain	<3.0ppb		2.2 ppb									
	WF-5	1st Floor Classroom 2 Sink Mounted	Water Fountain-Non Cooler	5.1 ppb		<2.0 ppb									
	WF-6	1st Floor Classroom 3 Wall Mounted	Water Fountain-Porcelain	29 ppb	1.5 ppb	10 ppb									
	WF-7	1st Floor Classroom 3 Sink Mounted	Water Fountain-Non Cooler	140 ppb	1.5 ppb	7.4 ppb									
	WF-8	1st Floor Classroom 4 Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		<2.0 ppb									
	WF-9	1st Floor Classroom 5 Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		<2.0 ppb									
	WF-10	3rd Floor Classroom 6 Sink Mounted	Water Fountain-Non Cooler	4.3 ppb		2.9 ppb									
	WF-11	2nd Floor Classroom 7 Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		2.8 ppb									
	WF-12	2nd Floor Classroom 8 Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		<2.0 ppb									
	WF-13	2nd Floor Classroom 8A Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		<2.0 ppb									
	WF-14	2nd Floor Classroom 9 Sink Mounted	Water Fountain-Non Cooler	50 ppb	6.7 ppb	700 ppb	need work order								
	WF-15	2nd Floor Classroom 10	Water Fountain-Non Cooler	<3.0 ppb		2.8 ppb									
	WF-16	2nd Floor Classroom 9A Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		2.0 ppb									
	WF-17	2nd Floor Classroom 11 Sink Mounted	Water Fountain-Non Cooler	<3.0 ppb		<2.0 ppb									
	WF-18	2nd Floor Hall next to Classroom 10	Water Fountain-Porcelain	<3.0ppb		<2.0 ppb									
	WF-19	3rd Floor Classroom 13A	Water Fountain-Non Cooler	<3.0 ppb		<2.0 ppb									
	WF-20	3rd Floor Classroom 12A	Water Fountain-Non Cooler	<3.0 ppb		2.8 ppb									
	WF-21	3rd Floor Classroom 12 Sink Mounted	Water Fountain	Out of Service		<2.0 ppb	89667/See Note						Repaired Oct 15, 2015/ awaiting re-test to put back in service. Completed 5112016		
	WF-22	3rd Floor Classroom 13 Sink Mounted	Water Fountain	Out of Service		2.6 ppb	89667/See Note						Repaired Oct 15, 2015/ awaiting re-test to put back in service completed 5112016		
ROSA PARKS															
	SF-1	Kitchen across from refrigerators	Sink Faucet	4.1 ppb		4.36 ppb									
	SF-2	Kitchen Triple Sink-Left	Sink Faucet	6.9 ppb		6.44 ppb									
	SF-3	Kitchen Triple Sink-right	Sink Faucet	8.4 ppb		7.41 ppb									
	SF-4	Kitchen Single Sink	Sink Faucet porcelain	37 ppb	<3.0 ppb	7.51 ppb									
	SF-5	Kitchen single sink	Sink Faucet	N/A		8.54 ppb									
	SF-6	Nurse's Office	Sink Faucet	N/A		7.8 ppb									
	WF-1	Across From Gym	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
	WF-2	Next to Room 112	Water Fountain-Elkay	6.1 ppb		7.14 ppb									
	WF-3	Across from Room 104	Water Fountain-Elkay	<3.0 ppb		<3.0 ppb									
SILK CITY															
	SF-1	Basement Kitchen - small	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-2	Basement Kitchen -Left-Large	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-3	Basement Kitchen-Right-Large	Sink Faucet	3.2 ppb		5.47 ppb									
	SF-4	Teachers Lounge	Sink Faucet	<3.0 ppb		<3.0 ppb									
	SF-5	Basement Nurses Office	Sink Faucet	14 ppb		48.8 ppb	96164	tentative week of May 30th							
	SF-6	Science Room B-3 by Teachers Area	Sink Faucet	12ppb		9.77 ppb									
	SF-7	Science Room B-3 Back Wall left	Sink Faucet	3.7ppb		11.1 ppb									

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
	SF-8	Science Room B-3 Back wall right	Sink Faucet	n/a		8.77 ppb									
	SF-9	Science Room B-3 Island Sink	Sink Faucet	n/a		<3.0 ppb									
	SF-10	B1 Discipline Room	Sink Faucet	n/a		<3.0 ppb									
	WF-1	Basement next to Girls Room	Water Fountain-Stainless	<3.0 ppb		<3.0 ppb									
	WF-2	Basement next to Boys Room	Water Fountain	<3.0 ppb		<3.0 ppb									
	WF-3	1st Floor next to Girls Room	Water Fountain	<3.0 ppb		<3.0 ppb									
	WF-4	1st Floor next to Boys Room	Water Fountain	<3.0 ppb		<3.0 ppb									
	WF-5	2nd Floor next to Mens Room	Water Fountain	<3.0 ppb		<3.0 ppb									
	WF-6	3rd Floor next to Ladies Room	Water Fountain	<3.0 ppb		out of order	88279	tentative week of May 30th							
	WF-7	4th Floor next to Mens Room	Water Fountain	<3.0 ppb		3.88 ppb									
ST MARY'S															
	SF-1	Kitchen Double Sink #1	Sink Faucet	8.1 ppb		7.0 ppb									
	SF-2	Kitchen Double Sink #2	Sink Faucet	7.6 ppb		83 ppb	95762	need answer					See Chief's email 4/27/2016		
	SF-3	Kitchen Double Sink #3	Sink Faucet	3.6 ppb		3.7 ppb									
	SF-4	Kitchen Double Sink #4	Sink Faucet	5.9 ppb		6.9 ppb									
	SF-5	Nurses Office	Sink Faucet	<3.0 ppb		<2.0 ppb									
	WF-1	Basement Cafeteria	Water Fountain-Halsey Taylor	6.0 ppb		3.5 ppb									
	WF-2	1st Floor Girls Restroom	Water Fountain-Cooler-Elkay	<3.0 ppb		<2.0 ppb									
	WF-3	1nd Floor Boys Restroom	Water Fountain-Cooler-Elkay	<3.0 ppb		<2.0 ppb									
	WF-4	Classroom 10	Water Fountain-Bubbler-Elkay	<3.0 ppb		<2.0 ppb									
	WF-5	Classroom 11	Water Fountain-Bubbler-Elkay	N/A		3.7 ppb									
SMITH ST/YMA															
	SF-1	Kitchen Basement - Large	Sink Faucet	6.4 ppb		2.0 ppb									
	SF-2	Kitchen Basement - Ceramic	Sink Faucet	<3.0 ppb		N/A see notes							Hand washing sink only		
	SF-3	Nurse's Office	Sink Faucet	n/a		10 ppb									
	SF-4	3rd Floor Teacher's lounge Bathroom	Sink Faucet	n/a		<2.0 ppb									
	WF-1	1st Floor next to Main Office	Water Fountain-Stainless	<3.0 ppb		<2.0 ppb									
BORIS KROLL/GFA															
	SF-1	Kitchen	Triple Sink-right	<3.0 ppb		<2.0 ppb									
	SF-2	Kitchen	Triple Sink-center	<3.0 ppb		14 ppb									
	SF-3	Kitchen	Triple Sink-left	<3.0 ppb		<2.0 ppb									
	SF-4	Kitchen	Sink far right	n/a		<2.0 ppb									
	SF-5	Nurse's Office	Sink Faucet	n/a		missed not sampled		tentative week May 30th							
	WF-1	Adj. Rm. 116 Left	Water Fountain	<3.0 ppb		out of order		tentative week May 30th					ONE WAS SAMPLED AND THE OTHER BROKEN		
	WF-2	Adj. Rm. 116 Right	Water Fountain	<3.0 ppb		out of order		tentative week May 30th					ONE WAS SAMPLED AND THE OTHER BROKEN		
	WF-3	Science Room next to B-3 by teachers area (Rm. 207)	Water Fountain-Elkay-Chiller	<3.0ppb		<2.0 ppb									
COLT ST./HARP/YES															
	WF-1	7th Floor Corridor	water fountain		Bldg. not in Service	<2.0 ppb							Bldg. came online January 4 2016		
	WF-2	6th Floor Corridor	water fountain			<2.0 ppb									
	WF-3	5th Floor Corridor	water fountain			<2.0 ppb									
	WF-4	4th Floor Corridor	water fountain			<2.0 ppb									
	WF-5	3rd Floor Corridor	water fountain			<2.0 ppb									
	WF-6	2nd Floor Corridor	water fountain			<2.0 ppb									
	SF-1	Nurse's Office	sink faucet			<2.0 ppb									
	SF-2	Dental Office	sink faucet			<2.0 ppb									
	SF-3	Rm 704 Teacher's Lounge	sink faucet			<2.0 ppb									
	SF-4	Kitchen next to warmer	sink faucet			<2.0 ppb									
	SF-5	Kitchen next to larger sink	sink faucet			2.3 ppb									
	SF-6	Kitchen back wall	sink faucet			<2.0 ppb									
DELAWARE AVE															
	SF-1	Kitchen admin coffee maker	coffee /sink faucet			<2.0 ppb									
	SF-2	Kitchen near espresso Machine opposite serving counter	sink faucet			2.0 ppb									
	SF-3	Kitchen opposite serving counter near toaster	sink faucet			2.1 ppb									
	SF-4	Kitchen opposite stove serving counter	sink faucet			6.9 ppb									
	SF-5	Kitchen SF for dish left	sink faucet			2.1 ppb									
	SF-6	Kitchen SF for dish right	sink faucet			5.1 ppb									
	SF-7	Kitchen near Hobart mixer & Microwave	sink faucet			2.2 ppb									
	SF-8	Kitchen by Fridge & meat slicer	sink faucet			<2.0 ppb									
	SF-9	2nd fl. Kitchen by elevator	sink faucet			<2.0 ppb									
	SF-10	2nd fl. Kitchen by Legal dept.	sink faucet			4.2 ppb									
	SF-11	Kitchen 3rd floor by elevator	sink faucet			<2.0 ppb									
	SF-12	Kitchen 4th floor	sink faucet			<2.0 ppb									
	WF-1	1st floor by restroom	water fountain			<2.0 ppb									
	WF-2	2nd floor kitchen by elevator	water fountain			<2.0 ppb									
	WF-3	Kitchen 3rd floor	water fountain			<2.0 ppb									
	WF-4	Kitchen 4th floor	water fountain			<2.0 ppb									
SHERIDAN AVE															
	SF-1	Benito's office Kitchen upstairs	sink faucet	N/A		<2.0 ppb									
	SF-2	Kitchen In Food Area (behind conference room warehouse)	sink faucet	N/A		<2.0 ppb									
	SF-3	Kitchen Upstairs Dept of Food Services	sink faucet	N/A		13 ppb									
COMBO - Water fountain and Sink Faucet combined															
	WF - Water Fountain			must sample											
	SF - Sink Faucet			under action level											
	N/S - No Sink														
	N/A - Not Accessable														
	N/D - Non Detect														
	HW-Corridor														
	F-flush														

Paterson Public Schools
Lead Testing Results

School Name	ID#	Location	Type/ Source	2014-2015 Test Draw/Flush Results	Re-Test 2014-2015 Draw/Flush Results	2016 Test Draw/Flush Results	Work Order #	Re-Test 2016 Draw/Flush Results	TTI Project ID Number	Number of Samples	Number of Hits	Outlet Sample ID	Notes / Recommendations Other	Filter/Installed Yes/No Date:	Cartridge ChangeDate:
FD- first draw															
missed or inaccessible															
under action level															
* see notes															